



NOTICE TO ALL CONTRACTORS

RULE 6-112 (3)(d) and 12-310

Support for the Attachment of Overhead Supply or Consumer's Service Conductors

For the purposes of this rule "ground normally accessible to pedestrians" includes patios, decks, balconies, porches, ladders, stairs, fire escapes or similar locations; a minimum vertical clearance of 3.5 m shall be maintained. In addition to the vertical clearance, a minimum horizontal clearance of 1 m shall also be maintained from these locations.