

Region	Settlement	Monthly Fire Alarm System Test and Inspection Record
		(Reference Clauses 3.7 &4.2.1)
Building Asset Number		Building Name:

DATE	INSF	PECT	FIRE ALARM SYSTEM				BATTERY			VOICE COMMUNICATION						
YEAR: 20	SYSTEM TROUBLE SIGNAL INDICATOR "OFF"	POWER INDICATION LAMP "ON"	LOCATION OF ALARM INITATING DEVICES	OPERATION AND INSPECTION OF ONE INITATING FIELD DEVICE - ROTATIONAL	ALERT/ALARM SIGNAL CONFIRMED - ROTATIONAL	INSPECT (REQUIRED ANNUNCIATOR): TESTED DEVICE ANNUNCIATES CORRECTLY	OPERATION OF COMMON AUDIBLE AND VISUAL TROUBLE SIGNAL CONFIRMED	TERMINALS CLEANED AND LUBRICATED	TERMINAL CLAMPS SECURE	ELECTROLYTE LEVEL AND SPECIFIC GRAVITY TO SPECIFICATIONS	LOCATION OF EMERGENCY TELEPHONE	TEST (ROTATIONAL): ONE EMERGENCY TELEPHONE FOR TWO- WAY COMMUNICATION AND INDICATION	LOCATION OF VOICE PAGE ZONE	TEST (ROTATIONAL): VOICE PAGING TO ONE ZONE	PERSON CONDUCTING TEST (SIGNATURE)	DEPARTMENT OR COMPANY CONDUCTING TEST
JAN																
FEB																
MAR																
APR																
MAY																
JUNE																
JULY																
AUG																
SEPT																
ОСТ																
NOV																
DEC																

 $\sqrt{-SATISFACTORY}$  X – UNSATISFACTORY

N/A – NOT APPLICABLE

N/T – NOT TESTED

## **NOTE:**

- National Fire Code of Canada (NFCC) requires that these records be retained a minimum of two (2) years.
- Tests to be conducted in accordance with this Standard (CAN/ULC-S536).
- The monthly test is not required during the month that the annual test is completed.