

Self-Contained Meter Isolation (≤ 200 Amps, >300 Volts Line to line)

For self-contained meter (≤ 200 Amps) services with a voltage greater than 300 voltage line to line, a disconnect must be installed between source and the meter.

