



# NOTICE TO ALL CONTRACTORS

May 16, 2017

## RULE 6-112 (2)(d)

### Support for the Attachment of Overhead Supply or Consumer's Service Conductors

For the purposes of this rule “ground normally accessible to pedestrians” includes patios, decks, balconies, porches, ladders, stairs, fire escapes or similar locations; a minimum vertical clearance of 3.5 m shall be maintained. In addition to the vertical clearance, a minimum horizontal clearance of 1 m shall also be maintained from these locations.