



## EMERGENCY/STANDBY GENERATOR WEEKLY INSPECTION

Obtain clearance from the building occupants before running the generator.

### Check Before Starting Test

Day Tank Fuel Level		Gen Set Oil Level		Coolant Level	Battery Fluid Level		Block Heater Operation	Fuel Transfer Pump	Check for Leaks	Check Fan Belts
Electric Starter	Air Control Louvers	Panel Covers	Annunciator Lamps	Panel Settings		Visual & Audible Signals	Battery Terminals	Charger Connections	Charger Operation	
<b>Volts</b>				<b>Amps</b>			Frequency	<b>After 10 Min</b>		Total Unit Hours
L1-L0	L1-L2	L1-L3	L2-L3	PH1	PH2	PH3		Oil Pressure	Water Temp	

Signature \_\_\_\_\_

Date \_\_\_\_\_

### Check Before Starting Test

Day Tank Fuel Level		Gen Set Oil Level		Coolant Level	Battery Fluid Level		Block Heater Operation	Fuel Transfer Pump	Check for Leaks	Check Fan Belts
Electric Starter	Air Control Louvers	Panel Covers	Annunciator Lamps	Panel Settings		Visual & Audible Signals	Battery Terminals	Charger Connections	Charger Operation	
<b>Volts</b>				<b>Amps</b>			Frequency	<b>After 10 Min</b>		Total Unit Hours
L1-L0	L1-L2	L1-L3	L2-L3	PH1	PH2	PH3		Oil Pressure	Water Temp	

Signature \_\_\_\_\_

Date \_\_\_\_\_

### Check Before Starting Test

Day Tank Fuel Level		Gen Set Oil Level		Coolant Level	Battery Fluid Level		Block Heater Operation	Fuel Transfer Pump	Check for Leaks	Check Fan Belts
Electric Starter	Air Control Louvers	Panel Covers	Annunciator Lamps	Panel Settings		Visual & Audible Signals	Battery Terminals	Charger Connections	Charger Operation	
<b>Volts</b>				<b>Amps</b>			Frequency	<b>After 10 Min</b>		Total Unit Hours
L1-L0	L1-L2	L1-L3	L2-L3	PH1	PH2	PH3		Oil Pressure	Water Temp	

Signature \_\_\_\_\_

Date \_\_\_\_\_

**Check Before Starting Test**

Day Tank Fuel Level		Gen Set Oil Level		Coolant Level	Battery Fluid Level		Block Heater Operation	Fuel Transfer Pump	Check for Leaks	Check Fan Belts
Electric Starter	Air Control Louvers	Panel Covers		Annunciator Lamps	Panel Settings		Visual & Audible Signals	Battery Terminals	Charger Connections	Charger Operation
<b>Volts</b>				<b>Amps</b>			Frequency	<b>After 10 Min</b>		Total Unit Hours
L1-L0	L1-L2	L1-L3	L2-L3	PH1	PH2	PH3		Oil Pressure	Water Temp	

Signature \_\_\_\_\_

Date \_\_\_\_\_

THIS LOG SHEET COVERS A FOUR (4) WEEK PERIOD FROM: \_\_\_\_\_ TO: \_\_\_\_\_